

CERTIFICATE

Certified Passive House Component


ID: 1353cs03 valid until 31. December 2019

Passive House Institute

Dr. Wolfgang Feist

64342 Darmstadt

GERMANY



Category **Wall system | Insulated formwork blocks**
Manufacturer **VARIANT-HAUS-GROUP ICF Manufacturing & Sales GmbH**
Frankfurt am Main
GERMANY
Product name **VARIANT HAUS**

This certificate for the cool, temperate climate zone was awarded based on the following criteria

Hygiene criterion

The minimum temperature factor of the interior surfaces is

$$f_{R_{si}=0,25m^2K/W} \geq 0,70$$

Comfort criterion

The U-value of the installed windows is

$$U_{w,i} \leq 0,85 \text{ W}/(\text{m}^2\text{K})$$

Efficiency criteria

Heat transfer coefficient of building envelope

$$U^*_{PHI} \leq 0,15 \text{ W}/(\text{m}^2\text{K})$$

Temperature factor of opaque junctions

$$f_{R_{si}=0,25m^2K/W} \geq 0,86$$

Thermal bridge-free design for key connection details

$$\Psi \leq 0,01 \text{ W}/(\text{mK})$$

An airtightness concept for all components and connection details was provided

cool, temperate climate



**CERTIFIED
COMPONENT**

Passive House Institute

cool, temperate climate

www.passivehouse.com